

ANALYTICAL RESULTS

STANDARD DELIVERABLES FORMAT

APL WORK ORDER NUMBER: 6070714

Wanaque School

Project: Wanaque School

A handwritten signature in black ink that reads "Brian Wood".

Brian Wood
Laboratory Director

All Results meet the requirements of the National Environmental Laboratory Accreditation Conference and/or State specific certifications as applicable.



AQUA PRO-TECH LABORATORIES
 Certified Environmental Testing

Analytical Results Summary

Wanaque School

Client: Wanaque School
APL Order ID: 6070714

Contact:
Received: 7/26/16 15:30

Sample ID/Analysis	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
6070714-01 (Drinking Water)		W01 Kitchen LT		Collected:	7/26/2016	8:00		
Total Metals								
ICP-MS Lead	EPA 200.8	7/27/16 11:13	7/27/16 11:13	0.0190			0.00200	mg/L
6070714-02 (Drinking Water)		W02 Kitchen CTR		Collected:	7/26/2016	8:05		
Total Metals								
ICP-MS Lead	EPA 200.8	7/27/16 11:18	7/27/16 11:18	0.0185			0.00200	mg/L
6070714-03 (Drinking Water)		W03 Kitchen RT		Collected:	7/26/2016	8:10		
Total Metals								
ICP-MS Lead	EPA 200.8	7/27/16 11:24	7/27/16 11:24	0.00829			0.00200	mg/L
6070714-04 (Drinking Water)		W04 Rm 4 Sink		Collected:	7/26/2016	8:15		
Total Metals								
ICP-MS Lead	EPA 200.8	7/27/16 11:30	7/27/16 11:30	0.0143			0.00200	mg/L
6070714-05 (Drinking Water)		W05 Rm 11 Bubbler		Collected:	7/26/2016	8:20		
Total Metals								
ICP-MS Lead	EPA 200.8	7/27/16 11:36	7/27/16 11:36	0.0470			0.00200	mg/L
6070714-06 (Drinking Water)		W06 Rm 12 Bubbler		Collected:	7/26/2016	8:25		
Total Metals								
ICP-MS Lead	EPA 200.8	7/27/16 11:42	7/27/16 11:42	0.0115			0.00200	mg/L
6070714-07 (Drinking Water)		W07 Rm 13 Bubbler		Collected:	7/26/2016	8:30		
Total Metals								
ICP-MS Lead	EPA 200.8	7/27/16 11:48	7/27/16 11:48	0.0130			0.00200	mg/L
6070714-08 (Drinking Water)		W08 Rm 14 Bubbler		Collected:	7/26/2016	8:35		
Total Metals								
ICP-MS Lead	EPA 200.8	7/27/16 11:54	7/27/16 11:54	0.00928			0.00200	mg/L
6070714-09 (Drinking Water)		W10 Rm 18		Collected:	7/26/2016	8:40		
Total Metals								
ICP-MS Lead	EPA 200.8	7/27/16 12:00	7/27/16 12:00	0.0206			0.00200	mg/L

FootNotes

RL - Reporting limit
 MDL - Minimum detection limit
 ND - Indicates compound analyzed for but not detected
 J - Indicates estimated value

B - Indicates compound found in associated blank
 E - Concentration exceeds highest calibration standard
 D - Indicates result is based on a dilution
 P - Greater than 25% diff. between 2 GC columns.



AQUA PRO-TECH LABORATORIES
 Certified Environmental Testing

Analytical Results Summary

Wanaque School

Client: Wanaque School
APL Order ID: 6070714

Contact:
Received: 7/26/16 15:30

Sample ID/Analysis	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
6070714-10 (Drinking Water)								
		W10 Rm 26		Collected:	7/26/2016	8:45		
Total Metals								
ICP-MS Lead	EPA 200.8	7/27/16 12:06	7/27/16 12:06	0.0151			0.00200	mg/L

FootNotes

RL - Reporting limit
 MDL - Minimum detection limit
 ND - Indicates compound analyzed for but not detected
 J - Indicates estimated value

B - Indicates compound found in associated blank
 E - Concentration exceeds highest calibration standard
 D - Indicates result is based on a dilution
 P - Greater than 25% diff. between 2 GC columns.

APL 6070714

7/26 8-830

AQUA PRO-TECH LABORATORIES



www.aquaprotechlabs.com

1275 BLOOMFIELD AVENUE • BUILDING 6
FAIRFIELD, NEW JERSEY 07004

TEL: 973.227.0422
FAX: 973.227.2813

CHAIN OF CUSTODY

PAGE ___ OF ___

TURN-AROUND TIME

- APL STANDARD 2 weeks
- RUSH (choose one below)
 - 24 hr. date & time required
 - 48 hr. date & time required
 - 72 hr. date & time required
 - 1 week

- REPORT FORMAT**
 - RESULTS ONLY
 - NJ DEP REDUCED
 - NJ DEP FULL
 - STATE FORMS/E2 REPORTING
 - ELECTRONIC FORMAT**
 - EMAIL DELIVERY
 - HAZSITE EDD
 - EXCEL
- PWSID# _____ SRP# _____

CLIENT: <u>Wanaque School</u>	SEND REPORT TO: <u>SAME</u>
ADDRESS: <u>1 First Ave</u>	ADDRESS:
<u>WANAQUE NJ 07420</u>	
PHONE: <u>862-203-9068</u>	PHONE:
E-MAIL:	FAX:
PROJECT NAME:	SEND INVOICE TO:
PROJECT MGR:	ADDRESS:
PROJECT or PO #:	SAMPLED BY:

CONTAMINATION LEVEL

HIGH MEDIUM LOW

MATRIX ABBREVIATIONS: D - DRINKING WATER G - GROUNDWATER W - WASTEWATER S - SOIL SL - SLUDGE C - CONCRETE L - LAKE

APL Lab ID#	Sample Source: Field ID	Date	Time	Sample Type		M A T R I X	No. of Bottles	Preservative	Analysis Requested
				G R A B	C O M P				
<u>6070714-01</u>	<u>W01 Kitchen lt.</u>	<u>7/26/16</u>	<u>8:00A</u>				<u>1</u>		<u>LEAD</u>
<u>-02</u>	<u>W02 " ctr.</u>		<u>8:05A</u>						
<u>-03</u>	<u>W03 " rt.</u>		<u>8:10A</u>						
<u>-04</u>	<u>W04 Rm 4 sink</u>		<u>8:15A</u>						
<u>-05</u>	<u>W05 Rm 11 Bubble</u>		<u>8:20A</u>						
<u>-06</u>	<u>W06 Rm 12 "</u>		<u>8:25A</u>						
<u>-07</u>	<u>W07 Rm 13 "</u>		<u>8:30A</u>						
<u>-08</u>	<u>W08 Rm 14</u>		<u>8:35A</u>						
<u>-09</u>	<u>W09 Rm 14</u>		<u>8:40A</u>						
<u>-10</u>	<u>W10 Rm 26 Rm 1 E</u>		<u>8:45A</u>						

RELINQUISHED BY (Print) <u>JWP</u>	DATE <u>7-26-16</u>	RECEIVED BY (Print) <u>S.P.</u>
Signature <u>[Signature]</u>	Time <u>8:45</u>	Signature <u>[Signature]</u>
RELINQUISHED BY (Print) <u>[Signature]</u>	DATE <u>7-26-16</u>	RECEIVED BY (Print) <u>C. J.</u>
Signature <u>[Signature]</u>	Time <u>3:30PM</u>	Signature <u>[Signature]</u>
RELINQUISHED BY (Print)	DATE	RECEIVED BY (Print)
Signature	Time	Signature
COMMENTS/SPECIAL INSTRUCTIONS		
Cooler Temp. upon receipt at lab <u>3</u>		

CERTIFICATIONS: NELAP (National Environmental Laboratory Accreditation Program) NJDEP #07010 PADEP #68-02903 NYDOH #11634 CTPH #0233 US ARMY
By signing this Chain of Custody Agreement, customer expressly agrees to pay APL for all charges, reasonably incurred in connection with analysis and reporting for these samples